

March 23, 2007

SKAW PRE-CAST
JACK SKAW
26255 105TH ST.
NEW AUBURN WI 54757

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: SKAW PRE-CAST
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, SEPTIC/SIPHON, OR HOLDING/HOLDING
Model Number(s): 1568/1568
(48.25 L.L., 33.251 GAL/IN., 96" MAX. DEPTH OF BURY, 1551 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 775 G.P.D. WHEN USED AS A SEPTIC/PUMP OR SEPTIC/SIPHON TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20070111

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Four inch pipe inlet located in the edge of the tank cover.
 - Four inch discharge opening in riser.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Four inch pipe openings located near the bottom of the side or end wall for siphon, pump and holding tanks.
 - Steel locking cover for the access opening.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Eight inch threaded plugged opening in access cover.
 - Six-inch diameter opening in lower portion of the interior wall for siphon, pump and holding tanks.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on 07/22/2002 under product file number 20020145.

SKAW PRE-CAST
Page 2
20070145
March 23, 2007

A copy of a successful water tightness test report for this product must be submitted to this office prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov